

Chloramine Filter Test Report

Report No: L19112902

Model No: 63x38x250

Sample: Internal Test

Material: Chloramine Carbon

Test Date: 108.11.26

Origin: Taiwan

Item		Result	Unit
Residual chlorine after 3 minutes Flow 4 L/min Total 12 L	Before	2.04	ppm
	After	0.01	ppm
	Removal	99.51	%
pH Value	Originally	6.71	-
	After 3 min	9.6	-
Weight		327	g
Black Water		1200	ml
Differential Pressure		0.139	Kg/cm ²

Note:

1. The weight is the finished product carbon rods the weight.
2. The report is responsible for sample test only.